



Seismic SSI Analysis of Pile-Supported LNG Storage Tank



| Ground Motion | Free Field | Center of Base Slab (Tank) | | | Top of Inner Tank | | | Top of Outer Tank | | |
|---------------|------------|----------------------------|------|-----------|-------------------|------|-----------|-------------------|------|-----------|
| | | FB | SSI | SSI+InCoh | FB | SSI | SSI+InCoh | FB | SSI | SSI+InCoh |
| 1125A61E | 0.62 | 0.61 | 0.63 | 0.52 | 1.08 | 0.99 | 0.80 | 1.71 | 1.18 | 1.12 |
| 1125A61N | 0.45 | 0.45 | 0.48 | 0.36 | 0.71 | 0.75 | 0.60 | 1.20 | 1.06 | 1.03 |
| ABBAR_L | 0.77 | 0.73 | 0.64 | 0.57 | 1.72 | 1.87 | 1.39 | 1.85 | 1.77 | 1.89 |
| ABBAR_T | 0.62 | 0.62 | 0.61 | 0.56 | 1.82 | 1.92 | 1.64 | 1.89 | 1.72 | 1.51 |
| ASRIN_L | 0.35 | 0.34 | 0.34 | 0.25 | 0.64 | 0.68 | 0.46 | 0.83 | 0.85 | 0.75 |
| ASRIN_T | 0.38 | 0.37 | 0.38 | 0.35 | 0.62 | 0.57 | 0.60 | 0.90 | 0.87 | 0.82 |
| CBN090 | 0.40 | 0.40 | 0.40 | 0.36 | 1.17 | 1.18 | 0.69 | 0.77 | 0.81 | 0.61 |
| CBN360 | 0.50 | 0.50 | 0.49 | 0.40 | 1.27 | 1.33 | 0.83 | 0.69 | 0.52 | 0.58 |
| DAY_LN | 0.69 | 0.67 | 0.61 | 0.56 | 1.03 | 1.30 | 0.98 | 2.01 | 1.33 | 1.37 |
| DAY_TR | 0.48 | 0.47 | 0.53 | 0.50 | 1.00 | 1.18 | 1.02 | 0.97 | 1.06 | 1.01 |
| GO1230 | 0.40 | 0.40 | 0.37 | 0.31 | 0.72 | 0.66 | 0.56 | 1.04 | 1.02 | 0.85 |
| GO1320 | 0.73 | 0.73 | 0.67 | 0.61 | 1.21 | 1.19 | 1.13 | 1.74 | 1.45 | 1.13 |
| LCN260 | 0.45 | 0.45 | 0.40 | 0.34 | 0.73 | 0.65 | 0.62 | 1.43 | 1.21 | 1.27 |
| LCN345 | 0.42 | 0.42 | 0.40 | 0.33 | 0.76 | 0.75 | 0.64 | 1.08 | 1.10 | 0.84 |
| Average | 0.52 | 0.51 | 0.50 | 0.43 | 1.04 | 1.07 | 0.85 | 1.29 | 1.14 | 1.06 |

MTR/SASSI was used to analyze the seismic SSI response of a LNG tank to assess whether the horizontal response of the tank could be optimized by considering the foundation kinematic SSI and incoherent ground motion effects. The SSI model consisted of a lumped-parameter model of inner steel and outer concrete tanks incorporating hydrodynamic effects and a detailed model of the foundation incorporating over 300 cast-in-place concrete piles penetrating a layered soil system. The results of the analysis were used in the preliminary tank and foundation design.